

**CITY OF RUSSELLVILLE, KENTUCKY
ORDINANCE 2021-07**

**AN ORDINANCE AMENDING ARTICLE VI OF ORDINANCE 2016-05 RELATING TO
POLLUTANT DISCHARGE LIMITATIONS FOR THE CITY OF RUSSELLVILLE'S
PRETREATMENT PROGRAM**

WHEREAS, City of Russellville, Kentucky, Ordinance 2005-12, subsequently amended in Ordinance 2016-05, established a Pretreatment Program to establish requirements for direct and indirect contributors into the wastewater collection and treatment system of the City of Russellville and to enable the City to comply with all applicable state and federal laws and regulations; AND

WHEREAS, it has become necessary to revise and amend Article VI of said ordinances to include revisions and additions to the pollutant discharge limitations in order to continue in compliance with state and federal regulations regarding the Pretreatment Program.

NOW, THEREFORE, BE IT ORDAINED, by the City Council of Russellville, Kentucky as follows:

SECTION I. SUBSTANTIVE AMENDMENTS.

Ordinance 2016-05, is hereby amended as follows:

ARTICLE VI-POLLUTANT DISCHARGE LIMITS

B. Restricted Discharges

14. The following limitations are established for characteristics of any wastewaters to be discharged into the City of Russellville's sewer system. All significant industrial users must comply with these limitations where they are more stringent than applicable State and/or Federal Regulations. Based upon the sampling program at the Russellville Wastewater Treatment Plant, the limitations may be adjusted to reflect the POTW's needs. These local limits are established to protect against pass through, interference, inhibition and biosolids contamination. Additional and/or more stringent limits may be necessary if any pass through, contamination and/or interference are detected.

RUSSELLVILLE PLANT PROTECTION CRITERIA

<u>Parameter</u>	<u>Maximum Daily Limits (mg/l)</u>	
Arsenic, total	0.39	mg/l
Cadmium, total	0.016	mg/l
Chromium, total	1.71	mg/l
Chromium, Hexavalent	0.42	mg/l
Copper, total	0.74	mg/l
Cyanide, Amenable	0.20 <u>0.13</u>	mg/l
Lead	0.39	mg/l
Mercury	0.036 <u>0.001</u>	mg/l
Nickel	2.49 <u>1.82</u>	mg/l
PCBs, Total	<0.0005	mg/l
Selenium	0.13	mg/l
Silver	0.69	mg/l
Zinc	1.48	mg/l

SECTION II. SEVERABILITY.

The provisions of this Ordinance are severable. If any sentence, clause, or part of this Ordinance or the application thereof to any particular state of case is for any reason found to be unconstitutional, illegal or invalid, such unconstitutionality, illegality or invalidity shall not affect or repeal any of the remaining provisions, sentences, clauses or sections or parts of this Ordinance, it being the legislative intent of this body to ordain and in act each other.

SECTION III. REPEAL OF EXISTING ORDINANCES.

All ordinances or parts of ordinances in conflict herewith now in effect, to the extent of said conflict, are hereby repealed.

SECTION IV. EFFECTIVE DATE.

This ordinance shall become effective upon passage and publication as required by law.

* * *

FIRST READING conducted on July 6, 2021.

SECOND READING AND PASSAGE on July 20, 2021.

APPROVED:

By: Mark Stratton
Mark Stratton, Mayor
City of Russellville

ATTEST:

By: Robert Nishibun
Robert Nishibun, City Clerk
City of Russellville

At a meeting of the City Council of the City of Russellville, Kentucky, held on July
20, 2021., the foregoing ordinance was adopted, after full discussion, by the following vote:

AYES:

NAYS:

ABSENT:

ABSTAINING:

Pat Bell

Bill Decker

Diane Walker

Larry Wilcutt

Sandra Kinser

Jimmy Davenport